

Test protocol

İleri Kalıpcılık Makina Elektrik San. Ve Tic. Ltd. Şti.



Order : KURTOĞLU 47 C
Test number: 020
Tester : FEHİMİ OLMUŞ

Date: 13.10.2010

Characteristiques of element

Type of element : ALÜMİNYUM
Opening type : ÇİFT AÇILIM
Overall Dim. (W x H) : 1.600 x 2.000 m Area : 3.200 m²
Opening Vent (W x H) : 0.750 x 1.460 m Area : 1.095 m²
Seal length : 4.420 m

Reference of Profiles

Frame :	Sill Detail :
Sash :	Transom :
Mullion :	Glazing bead :
Sealing :	Drip Bar :
Hardware :	Other :
Material :	Locking :
Finish :	Hinges :

Glazing

Type :	Filling :
Filling :	Glas area :
Glass Dimensions :	Other :

Rolling shutter box

Classification

Nominal : Airloss 3	Deformation 30	Beating rain A7
Estimated: Airloss 4	Deformation 3C	Beating rain A7

Remark:

Place:.....

Date:13.10.2010

Tester:.....*FEHİMİ OLMUŞ*

İLERİ KALIPCILIK LTD.ŞTİ

LABORATUVARI

FEHİMİ OLMUŞ